

Questions/ Answers

25-4090-01 Burnet County Annex Renovation/Expansion

10-22-24

Are there any details or additional information concerning the required scope of work for any new Fire Suppression or Fire Alarm systems. The drawings do not indicate anything for Fire Suppression, and only a few notes concerning smoke detectors and NFPA standard for Fire Alarm. There is no sprinkler work for this building.

10-22-24

Additionally, I see details concerning the stair nosings and risers, and the related handrail and guardrail, but there doesn't seem to be any information on what the structure of the stair is meant to be (i.e. steel, wood, engineered wood, etc...). Can you please clarify? The stair is meant to be wood.

10-22-24

In Table 8, Section 3, of the Statement of Qualifications it asks for "Supplier Name(s)" and includes "Access Controls". What access controls would be the scope of the General contractor on this project? This was an oversight and should have been removed. You can disregard that.